

INSTALLED PUMPING CAPACITY
SAN FERNANDO CATAÑO (Puente Wilson) FACILITY
(Coordinates: 18.4383, -66.1171)

Amount of Installed Flood Control Pumps:	4 units
Individual Pump Capacity:	
Pump # 1: working	68 k gpm
Pump # 2: working	68 K gpm
Pump # 3: working	35 K gpm
Pump # 4: damaged	68 K gpm
Total Pumping Capacity (Actual):	171 K gpm
Design Pumping Capacity:	239 K gpm
Supplementary Pumping Capacity Installed:	48 K gpm

Enclosure # 1 provides a delimitation of the Hydraulic Area being serviced.

CASA DE BOMBAS SAN FERNANDO

